Bauaufsichtlich anerkannte Prüf-, Überwachungs- und Zertifizierungsstelle
Prüfstelle für Feuerlöschmittel und -geräte
DIN EN ISO/IEC 17025: D-PL-17819-01-00
DIN EN ISO/IEC 17065: D-ZE-17819-01-00
DIN EN ISO/IEC 17020: D-IS-17819-01-00
ZLS-GS-0066
Notified Body no. 0767

MPA Dresden

EN 3 APPROVAL CERTIFICATE

Approval number: **SP 85/10**

This is to certify that the **"BAVARIA®" EN 3 fire extinguisher** with 1 kg ABC dry chemical powder has been type approved with the above mentioned approval number.

Approval specifications: **EN 3-7 : 2004 + A1 : 2007 in conjunction with the requirements of EN 3-10 : 2009**

Test report no.: **20160261/EG 126 *) in conjunction with the approval certificate no. SP 85/10 dated 2010-05-31**

Holder of the certificate: **BAVARIA EGYPT S.A.E., 17, Emad El Din St., 11111 Cairo, Egypt**

Manufacturer: **BAVARIA EGYPT S.A.E., Gisr El Suez St. Block 109-Industrial Zone, Ismailia Desert Road, 11511 Cairo, Egypt**

Model name:	**Tigra 1**	**Trade mark:**	**BAVARIA®**
Assembly drawing no.:	**20 T2010**	**List of parts no.**	**20 T2010**
Fire extinguishing medium:	**ABC BAVARIA EXTRA POWDER** Reference no. SP 67/09	**Operation device:**	**Pulling (safety) device and key**
Propellant:	**16 g CO_2, internal cartridge**	**Special detail:**	**Nozzle diameter 3,8 mm**
Test fire rating:	**8 A and 34 B according to EN 3-7**	**Range of operating temperature:**	**- 30 °C to 60 °C**

Notes:

*) Modification / Supplementation:
- ABC BAVARIA SUPERLATIVE POWDER 45 / Reference no. SP 85/09
- Distribution also under the trade mark „ BAVARIA®" by the company BAVARIA Brandschutz Industrie GmbH & Co. KG, 93449 Waldmünchen

The fire extinguisher is tested in accordance with the standard EN 3-7. Conformity to EN 3-7 is attested.

The manufacture of the fire extinguisher is subject of the factory production control within the scope of a quality management system according to EN 3-10 and is subject of surveillance by MPA Dresden GmbH.

The holder of the certificate is authorized to affix the above stated approval number on the marking label of the approved corresponding fire extinguisher as long as the results of our regular inspections, proceeded according to clause 10 of EN 3-10, are satisfactory.

This approval certificate is valid solely for fire extinguishers which correspond with the submitted test samples and with the confirmed documents.

17 March 2016

Grad. Eng. Bernd Ruhle
Manager of the certification office

Prüfen • Überwachen • Zertifizieren • MPA Dresden GmbH

Vorlage 2.10 Rev.02